



TESTING SERVICES, INC.
817 SHOWALTER AVE. • P.O. BOX 2041
DALTON, GEORGIA 30722-2041
PHONE: (706) 226-1400 • FAX: (706) 226-6118

NVLAB CODE: 100108-0

TEST REPORT

CLIENT:	Shaw Contract	REPORT NUMBER:	58300C
	PO Drawer 2128	LAB TEST NUMBER:	2539-6668
	Dalton, GA 30722-2128	DATE:	June 14, 2013

SAMPLE ID:

Test #	MTR/XR #	Style	MO #	Roll #	Backing
060413-15	5T065	Hype Tile	D9806	QE03XYP	EcoWorx

Subject:

Testing Services Inc was instructed by the client to determine the flammability of finished textile floor covering materials when exposed to an ignition source under controlled laboratory conditions.

Test Method:

ASTM D-2859: Standard Test Method for Flammability of Finished Textile Floor Covering Materials

Code of Federal Regulations: 16 CFR 1631 (FF2-70) < 6ft & 24 ft²

Code of Federal Regulations: 16CFR 1630 (FF1-70) > 6ft & 24 ft²

Test Scope:

This test method is part of the standards for the surface flammability of carpets and rugs of the U.S. Consumer Product Safety Commission. The acceptance criteria of this standard calls for the charred portion of at least seven out of eight individual specimens not extend to within 1" of the steel frame placed on top of the sample when exposed to a centrally placed methenamine pill tablet.

Test Data:

Specimen Number	Un-charred Area
01	> 3"
02	> 3"
03	> 3"
04	> 3"
05	> 3"
06	> 3"
07	> 3"
08	> 3"

Test Summary

Pass	Failure	Status
8	0	Passes

Approved By:

Erle Miles Jr. VP
Testing Services Inc.