



Shaw Industries, Inc.  
P.O. Box 2128  
Dalton, GA 30722

charles.tidwell@shawinc.com  
Phone: 706-532-2234

---

## Central Laboratory Test Report

**Test Date:** 03-6-2017

**Test Location** – Shaw Central Laboratory

**Product Information:**

**Division:** Philadelphia

**Style:** 54844 Genius

**Test Conducted:** 16 CFR Part 1630 (FF 1-70) Methenamine Pill Test / Ignition Characteristics of Finished Textile Floor Coverings.

**Test Results:**

**Number of Specimens Tested:** 8

**Number of Specimens Passed:** 8

**Sample Meets or Exceeds the Requirements of 16 CFR Part 1630 (FF 1-70)**

Approved by: Charles Tidwell

Note: This report shall not be reproduced except in full, without the written approval of the laboratory.

\* This facility is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for the specific scope of accreditation under Lab Code 100193-0. This report is provided for the exclusive use of the client to whom it is addressed. Results of the report are related only to the material identified and tested. This report can not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.

