

**TESTING SERVICES, INC.**

817 SHOWALTER AVE., PO BOX 2041
 DALTON, GA 30722-2041
 PHONE: (706)226-1400 FAX: (706)226-6118

TEST REPORT

CLIENT:	Shaw Contract	REPORT NUMBER:	62398C-01
	PO Drawer 2128	LAB TEST NUMBER:	2666-1795
	Dalton, GA 30722-2128	DATE:	November 20, 2014
		PAGE:	1 of 1

Test Material:

Style	5T113 Fine Point 18x36
MO#	J1982
Backing	EcoWorx
Roll #	QA03VKA
Test #	R-141110-11042

Test Scope:

Testing Services Inc was instructed by the client to determine the flammability of finished textile floor covering materials when exposed to an ignition source under controlled laboratory conditions. This test method is part of the standards for the surface flammability of carpets and rugs of the U.S. Consumer Product Safety Commission. The acceptance criteria of this standard calls for the charred portion of at least seven out of eight individual specimens not extend to within 1" of the steel frame placed on top of the sample when exposed to a centrally placed methenamine pill tablet.

Test Method:

ASTM D2859-06(2011): Standard Test Method for Flammability of Finished Textile Floor Covering Materials

Test Data:

Specimen Number	Un-charred Area
01	> 3"
02	> 3"
03	> 3"
04	> 3"
05	> 3"
06	> 3"
07	> 3"
08	> 3"

Test Summary

Pass	Failure	Status
8	0	Passes

Approved By:

Erle Miles, Jr V.P., Testing Services Inc

TSi Accreditation:

Our laboratory is accredited with US Dept of Commerce, National Institute of Standards and Technology: ISO/IEC 17025:2005. Our code # is NVLAP 100108-0. However, it should be noted that some or all of the tests performed are not under our scope of accreditation due to the work not fully conforming to the standard, or it being outside the scope of our accreditation, or subcontracted. The above testing was under our scope of accreditation.

Uncertainty:

We undertake all assignments for our clients on a best effort basis. Our findings and judgments are based on the information to us using the latest test methods available.

OUR LETTERS AND REPORTS APPLY ONLY TO THE SAMPLE TESTED AND ARE NOT NECESSARILY INDICATIVE OF THE QUALITIES OF APPARENTLY IDENTICAL OR SIMILAR PRODUCTS. THESE LETTERS AND REPORTS ARE FOR THE USE ONLY OF THE CLIENT TO WHOM THEY ARE ADDRESSED AND THEIR COMMUNICATION TO ANY OTHERS OR THE USE OF THE NAME TESTING SERVICES, INC. MUST RECEIVE OUR PRIOR WRITTEN APPROVAL. THE REPORTS AND LETTERS, AND OUR NAME, OUR SEALS, OR OUR INSIGNIA ARE NOT UNDER ANY CIRCUMSTANCES TO BE USED IN ADVERTISING TO THE GENERAL PUBLIC.