



COMMERCIAL TESTING COMPANY

1215 South Hamilton Street • Dalton, Georgia 30720
Telephone (706) 278-3935 • Facsimile (706) 278-3936

Report Number 18-01126.3

Patcraft
Dalton, Georgia

Test Number 5151-6280
January 8, 2018

GSA Testing
Flammability – Methenamine Pill Test

Applicable Document: General Services Administration, National Furniture Center, 3FNE-00-591a *Technical Requirements Booklet for Carpet, Carpet Tiles and Carpet Cushion*, FSC Group 72, Part I, Section A dated April 30, 2002 and GSA Carpet Specification Guideline dated April 1, 2010.

Test Method: The pill test was conducted in accordance with 16 CFR Chapter II, Subchapter D, Part 1630, *Standard for the Surface Flammability of Carpets and Rugs (FF 1-70)*. For this test, an individual specimen meets the *Test Criteria* if the charred portion does not extend to within 1.0 inch of the edge of the hole in the flattening frame. The *Acceptance Criteria* is based on at least 7 of 8 specimens meeting the *Test Criteria* in order for the material to conform to this standard.

Material Tested:

GSA Contract Number: Pre Award

Roll Number: RP04AGT

Special Item Number: 31-301, 31-601

Backing: Ultra Loc

Identification: I0485 Camber

MO Number: P9600

Construction: Broadloom-Multilevel Loop

Shaw Test Number: R-171204-44684

Test Result:

Specimen Number								Acceptance Criteria
1	2	3	4	5	6	7	8	
Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass

Unless otherwise indicated, the test results presented herein comply with GSA Technical Requirements.

Commercial Testing Company

(Authorized Signature)

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. The test results presented in this report apply only to the samples tested and are not necessarily indicative of apparent identical or similar materials. Sample selection and identification were provided by the client. A sampling plan, if described in the referenced standard, was not necessarily followed. This report, or the name of Commercial Testing Company, shall not be used under any circumstance in advertising to the general public.

TESTED TO BE SURE® Since 1974